

PRODUCT SPECS



CLASS "0" RUBBER INSULATING GLOVES • LRIG-0-(LENGTH)-(GLOVE SIZE)

ARC FLASH PROTECTION



These rubber insulating gloves protect against electrical shock and should be tested every 6 months in accordance with ASTM F496, "Standard Specification for In Service Care of Insulating Gloves and Sleeves" at an authorized safety equipment testing facility. Type I natural rubber. Meet ASTM D120, IEC EN60903, and NFPA 70E standards.

Features

- Meets ASTM D120, NFPA 70E, and IEC EN60903 standards
- **Maximum use** voltage AC / DC 1,000 / 1,500
- **Proof test** voltage AC / DC 5,000 / 20,000
- Made from natural rubber
- Black color
- Red class color label for Class "0"
- Available in 11" or 14" lengths
- Color options available in red, yellow, blue TYPE II Salcor Rubber blue/orange
- Part # LRIG-0-(LENGTH)-(GLOVE SIZE)

WWW.CHICAGOPROTECTIVE.COM