



## T-Max<sup>®</sup> Tensioner Bracket Mounting Guidelines



1. Remove the two mounting bolts on the side of the motor where the bracket will be positioned. Loosen the bolts on the other side of the motor, tilt the motor and slide the tensioner bracket into position.
2. Replace the bolts but do not fully tighten until the bracket is in the proper position.
3. Mount the tensioner to the front of the bracket. Tensioner should not interfere with the belt path or either of the pulleys. Also, it should be as close to the middle of the belt span as possible. Keep the original belt path as close to the center of the tensioner as possible.
4. Once the bracket is in the proper location, tighten all four motor bolts. Ensure the pulleys are aligned.
5. Finish mounting the tensioner by referring to the T-Max<sup>®</sup> Tensioner installation instructions.

Below are diagrams of two different possible installations:

### Horizontal Motor Mount: Fan Turning Clockwise



### Vertical Motor mount: Fan Turning Counter-Clockwise



If you have any questions please contact a Fenner Drives Applications Engineer at 800-243-3374 or [ae@fennerdrives.com](mailto:ae@fennerdrives.com). To view our online videos, including T-Max Tensioners Installation, visit [www.youtube.com/fennerdrives](http://www.youtube.com/fennerdrives).