



G1825BC Eyewash, Pedestal Mounted, Stainless Steel Bowl and Cover

Application: Free standing, pedestal mounted eyewash. Unit has stainless steel cover to protect bowl from dust, dirt and other contaminants. Two GS-Plus[™] spray-type spray heads deliver a flood of water for rinsing eyes.

Spray Head Assembly: Two GS-Plus[™] spray heads. Each head has an internal flow control and filter to remove impurities from the water flow.

Valve: 1/2" IPS chrome plated brass stay-open ball valve. Valve is US-made with chrome plated brass ball and Teflon[®] seals.

Bowl: 11-1/2" stainless steel with bowl cover. Cover is raised automatically when flag handle is activated. Cover closes when handle is returned to closed position.

Pipe and Fittings: Schedule 40 galvanized steel. Furnished with orange polyethylene covers for vertical piping for high visibility and corrosion resistance.

Supply: 1/2" NPT female inlet.

Waste: 1-1/4" NPT female outlet.

Sign: ANSI-compliant identification sign.

Ouality Assurance: Valve, bowl and spray head assembly is factory assembled and water tested prior to shipment.

Available Options

- HFC Hand and foot control. Eyewash is activated by flag handle or foot treadle.
- HS Auxiliary hand-held drench hose for rinsing eyes, face or body.
- **TMV** G3600 thermostatic mixing valve precisely blends hot and cold water to deliver warm (tepid) water as required by ANSI Z358.1-2009. Refer to "Tempering Units" section for complete technical and product selection information.



Guardian Equipment 1140 N North Branch St Chicago, IL 60642

312 447 8100 телерноме 312 447 8101 FACSIMILE gesafety.com

Listed 8116. Units have been tested to and comply with ANSI Z358.1-2009 and the Uniform Plumbing Code.








Units have been tested to and comply with



Eyewashes

G1825BC Eyewash, Pedestal Mounted, Stainless Steel Bowl and Cover



Due to continuing product improvement, the information contained in this document is subject to change without notice. All dimensions are \pm 1/4" (6mm). rev. on rev. 0114

Guardian Equipment 1140 N North Branch St Chicago, IL 60642

312 447 8100 теlephone 312 447 8101 FACSIMILE gesafety.com

Listed 8116. Units have been tested to and comply with ANSI Z358.1-2009 and the Uniform Plumbing Code.







ETL Listed 101496. Units have been tested to and comply with ANSI Z358.1-2009.